

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3774-1457:102 Page 1 of 1

CATEGORY: Electric Locks

LISTEE: DynaLock Corp., 705 Emmett Street, Forestville, CT 06011-9470
Contact: *Glen Girard (860) 582-4761 Fax (860) 585-0338

DESIGN: Model 6450 exit sensor bar. Unit is intended to be used with separately listed burglary resistant electric locking mechanism as a non-latching request to exit device to un-lock electromagnetic locks. The unit is provided with a form C relay which allows the device to be used with both fail-safe and fail-secure devices. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12-24 V AC/DC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as non-latching electromagnetic locking device for non fire-rated doors. For indoor use only. Authority having jurisdiction shall be consulted prior to installation.

NOTE: Not intended for use in lieu of emergency panic hardware.

*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**